

Dillingham Water System

Consumer Confidence Report

PWSID#AK2260197

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The City of Dillingham public water system is a ground water system that gets water from two ground water wells. Well #2 is located in the Old Courthouse parking lot at 715 Seward Street. Well #5 is the new water well which is located in the High School parking lot at 135 Main Street. WL006 (Well #5 High School Well) is active and is part of the usual daily rotation. Initially the well was used for emergency purposes because there were issues after installation. However, the issues have been remedied and it has been in consistent use in 2021.

Source water assessment and its availability

A source water assessment for the groundwater well #2 - WL001 was completed in 2004 and the results of the assessment are:

The Wellhead/Surface Intake Susceptibility is Low.

The Aquifer Susceptibility is Very High.

The overall vulnerability to potential contaminants is:

Bacteria and Viruses is High;

Nitrates/Nitrites is High;
Volatile Organic Chemicals is High;
Inorganics/Heavy Metals is High;
Synthetic Organic Chemicals is Medium;
Other Organic Chemicals is High.

A source Water Assessment report for the groundwater well #5 (New Well) - WL006 has not been completed for this source.

The Drinking Water Source Protection (DWSP) group is no longer completing Source Water Assessment reports for public water system (PWS) sources. However, DWSP continues to delineate drinking water source protection areas for all PWS sources and furthers awareness of these protection areas through outreach efforts. DWSP encourages active protection efforts by promoting the development and implementation of DWSP plans by PWS and communities, as well as by providing passive protection efforts through reviewing and commenting on proposed permitted activities near PWS sources and ensuring agency loans and grants prioritize water quality improvement projects near PWS sources.

For assistance, please contact the DWSP coordinator at 907-269-7549, or toll free in Alaska at 1-866-956-7656. You can go to the DWSP website for more information at:
<https://dec.alaska.gov/eh/dw/dwp>.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Persons wishing to learn more about the City of Dillingham public water system may contact us using the contact information in this report.

Monitoring and reporting of compliance data violations

Asbestos

We are required to monitor for Asbestos on an annual basis and did not do so for 2022. We plan to monitor for Asbestos in 2023 and return to compliance. Some people who drink water containing asbestos more than the MCL over many years may have an increased risk of developing benign intestinal polyps.

Synthetic Organic Carbons (SOC)

We are required to sample for SOC on a quarterly basis and did not do so for the first, second, and third quarters of 2022. We submitted a waiver for SOC monitoring that went into effect in September of 2022 and were not required to monitor for SOC in the fourth quarter of 2022. We plan to submit an application to renew the SOC waiver for the 2023-2025 SOC monitoring period before September 30, 2024. We returned to compliance on 10/6/22. Some people who drink water containing SOC's in excess of the MCL over many years could experience problems with their liver or nervous system, problems with their kidneys, stomach or intestines, reproductive difficulties and may have an increased risk of getting cancer.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Dillingham Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the

State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	.09	.01	.09	2022	No	Water additive used to control microbes
Inorganic Contaminants								
Barium (ppm)	2	2	.0168	NA	NA	2019	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	.031	NA	NA	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Volatile Organic Contaminants								
Xylenes (ppm)	10	10	.00053	NA	NA	2021	No	Discharge from petroleum factories; Discharge from chemical factories
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.25	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	4.5	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Additional Contaminants

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water.

Contaminants	State MCL	Your Water	Violation	Explanation and Comment
Nickel	0 NA	1.94 ug/L	No	Leaching from metals in contact with drinking-water, such as pipes and fittings. Erosion of natural deposits.

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Robert Mawson
Address: PO Box 889 (Second Avenue West and Main Street)
Dillingham, AK 99576
Phone: 907-842-2260